

Sheet 1 of 3

Project: FIRE TEST FOR SOFT-SEATED
BALL VALVE

Certificate No.: M297-1/09 - 9587

Client: JC Fábricas de válvulas, S. A.

Office: Sant Joan Despí (BCN)

Client's Order No.:: ---

Date: 24.03.09

Order Status: Complete

Inspection dates

First: 24.03.09

Final: 24.03.09

This certificate is issued to

Messrs. **JC Fábricas de válvulas, S. A.**, upon their request that the undersigned Suveryor to this Society did attend their premises at their works in Sant Boi de Llobregat - Barcelona (Spain) for the purpose of witnessing the FIRE TEST in accordance with the requirements specified in API 607 and ISO 10497, on the following type of valve:

A manually operate J.C Ball Valve TL series of 2" bore 2", as per fig 315 A.I.T, 150# Body and Connector material A216 Gr.WCB

Trim: SEE DRAWING 090909

Marks:

- BODY : Col. AMV8 - CONNECTOR : Col. AJJ8

The test conducted on the valve previously subject to hydraulic pressure was as follows:

The valve in the closed position, filled with water under test pressure, was put in a box and exposed to flames with an environmental temperature in the region 750° C for a period of 30 minutes and established the leakage trough the seat and external to atmosphere during this period. The temperature was checked and recorded every two minutes, while leakages were determined using containers collecting the water leaked during burn period. Afterwards cool-down to 100° C. The valve seat and external hydrostatically tested to the appropriate test pressure and leakages recorded accordingly. Subsequently manually opened up under test pressure differential and finally the valve was fully hydrotested and leakages recorded.

All the following values were determined and recorded together with temperatures, times and pressures as shown on manufacturers Fire Safe Test Report no C297/09





Certificate No.: M297-1/09 - 9587 Office: Sant Joan Despí (BCN)

Date: 24.03.09 Sheet 2 of 3

- 1. Through-valve leakage during burn period SATISFACTORY.
- External leakage during burn and cool-down period SATISFACTORY.
- 3. Through-valve leakage during operational test SATISFACTORY.
- External leakage during operational test SATISFACTORY.
- 5. Operatibility to full open position and external leakage SATISFACTORY.

The valve was subject to a visual examination with satisfactory results and subsequently dismantled in order to verify that valves components comply with the drawing and parts list supplied by the manufacturer, while seat rings were found completely destroyed.

The manufacturers Fire Safe Test Report nº C297/09 and drawing 090909 herewith attached were satisfactory checked and signed.

The above is considered in accordance with the mentioned specifications requirements, therefore the subject valve has satisfactory passed the prescribed fire test and can be also qualified as follows.

DN	CLASS RATING	PN RATING
50 and below, 65, 80 100	150#, 300#	10, 16, 25, 40

Surveyor

Javier Aranda García

SGS Tecnos, S.A.

C/ Las Planns, 1 - Nave B Poligono Industrial Fontsanta 08970 Sant Joan Despi (Barcelona) Tel.: (34) 93 477 01 71 - 93 477 01 69

Fax: (34) 93 373 15 00

DOCUMENTS ATTACHED:

Sheets reviewed and stamped Accordingly.



Certificate No.: M297-1/09 - 9587 Office: Sant Joan Despí (BCN)

Date: 24.03.09 Sheet 3 of 3

090909

